



PD NO.:
PB240723-RAJC335.

REQUISITIONER: DMD c/o H. S. Galang ✓

THIS ORDER IS SUBJECT TO THE TERMS & CONDITIONS PRINTED AT THE BACK HEREOF:

AFG-LOG-008.F03
Rev. No. 0



REPUBLIKA NG PILIPINAS
Pambansang Korporasyon Sa Elektrisidad
(NATIONAL POWER CORPORATION)

PURCHASE ORDER

P.O. No. 059245-JVC

Page 2 of 4

This PO number must appear on all papers, invoices, packing list and correspondence.

TO: **INTEGRATED POWER & CONTROL PROVIDER, INC.**
2A 2F 8070, TANGUILE ST., COR. ESTRELLA AVE.
SAN ANTONIO VILL., MAKATI CITY

DATE: September 13, 2024

PD NO.:
PB240723-RAJC335

PO ITEM NO.	PR NO./ ITEM NO.	DESCRIPTION	QTY/UNIT OF MEAS	UNIT PRICE	AMOUNT																																																																																																				
		HO-FW24-010 / S/D & T OF NI-CAD BATT. FOR VARIOUS FWSD STATIONS																																																																																																							
	1.0	NICKEL-CADMIUM BATTERIES																																																																																																							
		<table><tr><th>ITEM</th><th>DESCRIPTION</th><th>TECHNICAL DATA</th><td></td><td></td></tr><tr><td>a.</td><td>Manufacturer</td><td>TECHNICAL ENGINEERING CO LTD</td><td></td><td></td></tr><tr><td>b.</td><td>Place of Manufacturer</td><td>TAIWAN</td><td></td><td></td></tr><tr><td>c.</td><td>Brand/model</td><td>TPL-102</td><td></td><td></td></tr><tr><td>d.</td><td>Battery Type</td><td>Nickel-Cadmium (N-Cad)</td><td></td><td></td></tr><tr><td>e.</td><td>Battery Voltage</td><td>1.2V</td><td></td><td></td></tr><tr><td>f.</td><td>Battery Capacity</td><td>102Ah</td><td></td><td></td></tr><tr><td>g.</td><td>No. of Cell/Group</td><td>Ten (1) cells/group</td><td></td><td></td></tr><tr><td>h.</td><td>Total Quantity</td><td>One hundred fifty (150) pieces</td><td></td><td></td></tr><tr><td>i.</td><td>Materials</td><td></td><td></td><td></td></tr><tr><td></td><td>I. Electrode Plate</td><td>Nickel Hydroxide and Cadmium Hydroxide</td><td></td><td></td></tr><tr><td></td><td>II. Housing</td><td>Nickel Hydroxide and Cadmium Hydroxide</td><td></td><td></td></tr><tr><td></td><td>III. Electrolyte Solutions</td><td>Potassium Hydroxide and Lithium Hydroxide</td><td></td><td></td></tr><tr><td></td><td>IV. Min/Max Electrolyte Solutions Level</td><td>Visible</td><td></td><td></td></tr><tr><td>j.</td><td>Content</td><td></td><td></td><td></td></tr><tr><td></td><td>Accessories to be Included in the supply</td><td></td><td></td><td></td></tr><tr><td></td><td>I. Insulated Battery Jumper Cable with Terminal Lugs</td><td>Insulated Battery Jumper Cable included with Terminal Lugs for the ten (10) cells/group terminals Quantity: 150 sets with 300 pcs. Bolts and 300 pcs nuts</td><td></td><td></td></tr><tr><td></td><td>II. Insulated Terminal Connector</td><td>Insulated Terminal Connector included for each of the ten (10) cells/group. (Quantity: 30 sets with bolts and nuts)</td><td></td><td></td></tr><tr><td></td><td>III. Battery Rack</td><td>Battery Rack for each of the ten (10) cells/group. Quantity: 15 units (please see attached design)</td><td></td><td></td></tr><tr><td></td><td>IV. Material</td><td>Galvanized steel</td><td></td><td></td></tr></table>				ITEM	DESCRIPTION	TECHNICAL DATA			a.	Manufacturer	TECHNICAL ENGINEERING CO LTD			b.	Place of Manufacturer	TAIWAN			c.	Brand/model	TPL-102			d.	Battery Type	Nickel-Cadmium (N-Cad)			e.	Battery Voltage	1.2V			f.	Battery Capacity	102Ah			g.	No. of Cell/Group	Ten (1) cells/group			h.	Total Quantity	One hundred fifty (150) pieces			i.	Materials					I. Electrode Plate	Nickel Hydroxide and Cadmium Hydroxide				II. Housing	Nickel Hydroxide and Cadmium Hydroxide				III. Electrolyte Solutions	Potassium Hydroxide and Lithium Hydroxide				IV. Min/Max Electrolyte Solutions Level	Visible			j.	Content					Accessories to be Included in the supply					I. Insulated Battery Jumper Cable with Terminal Lugs	Insulated Battery Jumper Cable included with Terminal Lugs for the ten (10) cells/group terminals Quantity: 150 sets with 300 pcs. Bolts and 300 pcs nuts				II. Insulated Terminal Connector	Insulated Terminal Connector included for each of the ten (10) cells/group. (Quantity: 30 sets with bolts and nuts)				III. Battery Rack	Battery Rack for each of the ten (10) cells/group. Quantity: 15 units (please see attached design)				IV. Material	Galvanized steel		
ITEM	DESCRIPTION	TECHNICAL DATA																																																																																																							
a.	Manufacturer	TECHNICAL ENGINEERING CO LTD																																																																																																							
b.	Place of Manufacturer	TAIWAN																																																																																																							
c.	Brand/model	TPL-102																																																																																																							
d.	Battery Type	Nickel-Cadmium (N-Cad)																																																																																																							
e.	Battery Voltage	1.2V																																																																																																							
f.	Battery Capacity	102Ah																																																																																																							
g.	No. of Cell/Group	Ten (1) cells/group																																																																																																							
h.	Total Quantity	One hundred fifty (150) pieces																																																																																																							
i.	Materials																																																																																																								
	I. Electrode Plate	Nickel Hydroxide and Cadmium Hydroxide																																																																																																							
	II. Housing	Nickel Hydroxide and Cadmium Hydroxide																																																																																																							
	III. Electrolyte Solutions	Potassium Hydroxide and Lithium Hydroxide																																																																																																							
	IV. Min/Max Electrolyte Solutions Level	Visible																																																																																																							
j.	Content																																																																																																								
	Accessories to be Included in the supply																																																																																																								
	I. Insulated Battery Jumper Cable with Terminal Lugs	Insulated Battery Jumper Cable included with Terminal Lugs for the ten (10) cells/group terminals Quantity: 150 sets with 300 pcs. Bolts and 300 pcs nuts																																																																																																							
	II. Insulated Terminal Connector	Insulated Terminal Connector included for each of the ten (10) cells/group. (Quantity: 30 sets with bolts and nuts)																																																																																																							
	III. Battery Rack	Battery Rack for each of the ten (10) cells/group. Quantity: 15 units (please see attached design)																																																																																																							
	IV. Material	Galvanized steel																																																																																																							

NATIONAL POWER CORPORATION
Building 1
ad corner Quezon Avenue, Diliman
Quezon City, PHILIPPINES

MSSPD - LOGISTICS DEPARTMENT
FAX NOS.: 8921-6048 / 8921-2468
Email: msspd@napocor.gov.ph

TEL. NOS.
8921-3541 to 80
8924-5494 / 5434 / 5284 / 5465



REPUBLIKA NG PILIPINAS
Pambansang Korporasyon Sa Elektrisidad
(NATIONAL POWER CORPORATION)

PURCHASE ORDER

P.O. No. 059245-JVC

Page 3 of 4

This PO number must appear on all papers, invoices, packing list and correspondence.

TO: **INTEGRATED POWER & CONTROL PROVIDER, INC.**
2A 2F 8070, TANGUILE ST., COR. ESTRELLA AVE.
SAN ANTONIO VILL., MAKATI CITY

DATE: September 13, 2024

PD NO.: PB240723-RAJC335

PO EM NO.	PR NO./ ITEM NO.	DESCRIPTION	QTY/UNIT OF MEAS	UNIT PRICE	AMOUNT																																																																												
		NO-FW24-010 / S/D & T OF NI-CAD BAT. FOR VARIOUS FFWSO STATIONS																																																																															
		2.0 BATTERY TESTER																																																																															
		<table><tr><th>ITEM</th><th>DESCRIPTION</th><th>TECHNICAL DATA</th><th></th></tr><tr><td>a.</td><td>Manufacturer</td><td>HIOKI</td><td></td></tr><tr><td>b.</td><td>Place of Manufacturer</td><td>Japan</td><td></td></tr><tr><td>c.</td><td>Brand/model</td><td>BT3554-51</td><td></td></tr><tr><td>d.</td><td>Battery Diagnostic Type</td><td>Impedance method</td><td></td></tr><tr><td>e.</td><td>Quantity</td><td>One (1) set</td><td></td></tr><tr><td>f.</td><td>Measurement Parameters</td><td></td><td></td></tr><tr><td></td><td>i. Battery Internal resistance</td><td>Supported</td><td></td></tr><tr><td></td><td>ii. Battery terminal voltage</td><td>Supported</td><td></td></tr><tr><td>g.</td><td>Comparator Function Warning/Display</td><td></td><td></td></tr><tr><td></td><td>i. Voltage low or high-value</td><td>Supported</td><td></td></tr><tr><td></td><td>ii. Audible tone warning (WARNING/FAIL)</td><td>Supported</td><td></td></tr><tr><td>h.</td><td>Battery Measurement</td><td>Supported</td><td></td></tr><tr><td>i.</td><td>Auto memory Function</td><td>Supported</td><td></td></tr><tr><td>j.</td><td>Auto hold Function</td><td>Supported</td><td></td></tr><tr><td>k.</td><td>Display</td><td>LCD with Backlight</td><td></td></tr><tr><td>l.</td><td>Communication Interface</td><td>USB</td><td></td></tr><tr><td>m.</td><td>Operating Temperature</td><td>≥40°C</td><td></td></tr><tr><td>n.</td><td>Power Supply</td><td>Size AA Alkaline Batteries</td><td></td></tr></table>	ITEM	DESCRIPTION	TECHNICAL DATA		a.	Manufacturer	HIOKI		b.	Place of Manufacturer	Japan		c.	Brand/model	BT3554-51		d.	Battery Diagnostic Type	Impedance method		e.	Quantity	One (1) set		f.	Measurement Parameters				i. Battery Internal resistance	Supported			ii. Battery terminal voltage	Supported		g.	Comparator Function Warning/Display				i. Voltage low or high-value	Supported			ii. Audible tone warning (WARNING/FAIL)	Supported		h.	Battery Measurement	Supported		i.	Auto memory Function	Supported		j.	Auto hold Function	Supported		k.	Display	LCD with Backlight		l.	Communication Interface	USB		m.	Operating Temperature	≥40°C		n.	Power Supply	Size AA Alkaline Batteries				
ITEM	DESCRIPTION	TECHNICAL DATA																																																																															
a.	Manufacturer	HIOKI																																																																															
b.	Place of Manufacturer	Japan																																																																															
c.	Brand/model	BT3554-51																																																																															
d.	Battery Diagnostic Type	Impedance method																																																																															
e.	Quantity	One (1) set																																																																															
f.	Measurement Parameters																																																																																
	i. Battery Internal resistance	Supported																																																																															
	ii. Battery terminal voltage	Supported																																																																															
g.	Comparator Function Warning/Display																																																																																
	i. Voltage low or high-value	Supported																																																																															
	ii. Audible tone warning (WARNING/FAIL)	Supported																																																																															
h.	Battery Measurement	Supported																																																																															
i.	Auto memory Function	Supported																																																																															
j.	Auto hold Function	Supported																																																																															
k.	Display	LCD with Backlight																																																																															
l.	Communication Interface	USB																																																																															
m.	Operating Temperature	≥40°C																																																																															
n.	Power Supply	Size AA Alkaline Batteries																																																																															

NATIONAL POWER CORPORATION
1991
Corner Quezon Avenue, Diliman
Quezon City, PHILIPPINES

MSSPD - LOGISTICS DEPARTMENT
FAX NOS.: 8921-6048 / 8921-2468
Email: msspd@napocor.gov.ph

TEL. NOS.
8921-3541 to 80
8924-5494 / 5434 / 5288



REPUBLIKA NG PILIPINAS
Pambansang Korporasyon Sa Elektrisidad
(NATIONAL POWER CORPORATION)

PURCHASE ORDER

P.O. No. 059245-JVC

Page 4 of 4

This PO number must appear on all papers, invoices, packing list and correspondence.

TO: INTEGRATED POWER & CONTROL PROVIDER, INC.
2A 2F 8070, TANGUILE ST., COR. ESTRELLA AVE.
SAN ANTONIO VILL., MAKATI CITY

DATE: September 13, 2024

PD NO.: PB240723-RAJC335

PO ITEM NO.	PR NO./ ITEM NO.	DESCRIPTION	QTY/UNIT OF MEAS	UNIT PRICE	AMOUNT
----------------	---------------------	-------------	---------------------	------------	--------

HO-FFW24-010 / S/D & T OF NI-CAD BAT. FOR VARIOUS FFWSO STATIONS

ITEM	DESCRIPTION	TECHNICAL DATA
o	Standard Compliance	
	I. EN 61010-2-030	EN 61010-2-030
	II. EMC EN 61326-1	EMC EN 61326-1
p	Accessories to be Included in the supply	
	I. Test leads	Included
	II. Proetecot case with neck strap	Included
	III. Carrying case	Included
	IV. Spare fuse set	Included

Documents to be Submitted Before or Upon Delivery:

- 1 "Certificate of Origin" from the Manufacturer for the Nickel Cadmium Battery;
- 2 "Warranty Certificate" for one (1) year against factory defect/quality;
- 3 Product Standard Compliance Certificate
- 4 User Manual

Note: All documents shall be submitted to the Office of the Manager, FFWSO for quotation and approval before the issuance of the acceptance certificate.

NATIONAL POWER CORPORATION
Building 1
ad corner Quezon Avenue, Diliman
Quezon City, PHILIPPINES

MSSPD - LOGISTICS DEPARTMENT
FAX NOS.: 8921-6048 / 8921-2468
Email: msspd@napocor.gov.ph

TEL. NOS.
8921-3541 to 80
8924-5494 / 5434 / 5284 / 5465