

National Power Corporation

SUPPLEMENTAL / BID BULLETIN NO. 2023-GOODS-011

to the Bidding Documents for the:

_	DESCRIPTION	PR NO./ ITB NO.
1	INSTALLATION OF AUXILLIARY TRASH RACK PANEL AT INTAKE CHANNEL OF AGUS 5 HPP	MG-A5M23-011/PB-2023-003, ITEM NO. 3

(Published on December 17, 2022, PhilGEPS)

All prospective bidders are hereby informed of the changes in some provisions of the tender documents as follows:

1. Changes in the schedule of Bid Submission and Opening:

To give ample time of Prospective Bidders to renew their Mayors permit and update the corresponding Annex "A" of their PhiGEPS Certificate, the Submission and Bid Opening of the above stated projects scheduled on January 10, 2023 will be postponed.

FROM	то
January 10, 2023 at 9:30AM	January 17, 2023 at 9:30AM

2. Section VII. Technical Specifications Conformity with the Technical Specifications – 3 Item 1.

Description	NPC Required Specifications	
	FROM	то
Support Braces	I-beams, 12"x12"x0.5"	Horizontal Support (I-beam); Width: 6.75in Depth: 14.5in Flange Thickness: 0.65in Web Thickness: 0.385in Vertical Support (I-beam); Width: 8in Depth: 12in Flange Thickness: 0.55in Web Thickness: 0.36in

NPC-009.F17 Rev.No.1 Page 1 of 2

BiR Road cor. Quezon Avenue, Diliman Quezon City 1100, Philippines

Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468

Websile: www.napocor.gov.ph





3. Additional Input to Section VII. Technical Specifications Conformity with the Technical Specifications – 1

Item No.	Scope of Works
9.	Submission of Test Certificate from independent party that the delivered materials with hot dip galvanized finish is tested in accordance to requirement/ standards of ASTM A123

Notes:

- All other terms published in the previous publication that are not amended by this publication shall remain thesame.
- For further clarification, you may contact us at (063)223-4604.

For the information and guidance of all concerned.

REYNANTE T. CIRUELA
Chairman, Bids and Awards Committee
Mindanao Generation

Date of Publication: December 29, 2022

NPC-009 F17 Rev.No.1 Page 2 of 2

BIR Road cor. Quezon Avenue, Diliman Quezon City 1100, Philippines Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468 Website: www.napocor.gov.ph



