



National Power Corporation

**SUPPLEMENTAL / BID BULLETIN NO. 2022-GOODS-073**

to the Bidding Documents for the:

**INSTALLATION OF AUTOMATIC FIRE SUPPRESSION**  
**AT AGUS 6 HPP CONTROL ROOM**

**PR NO. MG-A7T22-053/ PB-2022-016, ITEM NO.6)**

(Published on August 13, 2022, PhilGEPS)

All prospective bidders are hereby informed of the changes in some provisions of the tender documents as follows:

**Clarification:**

**1. Section VII. Technical Specifications**

Conformity with the Technical Specifications – 2

Scope of Works (Additional):

6. Installation, Integration and Programming of the new AFSS and other devices should be done online, deactivation of the FDAS FACP will not be allowed for uninterrupted protection from fire.

**2. Section VII. Technical Specifications**

Conformity with the Technical Specifications – 3

| ITEM | DESCRIPTION  | FROM  | TO   |
|------|--|---|--|
| 4    | <b>A. SUPPRESSION AGENT</b>  |   |  |
|      | With four (4) 12 Volts 40 Amp-Hr rechargeable Sealed Lead Acid (SLA) | Standard with Electronic addressing and Automatic Device Mapping feature  | <b>TECHNICAL SPECS OF BATTERY:</b><br>a. Manufacturer: By Supplier<br>b. Model Number/Part Number: By Supplier<br>c. Quantity: 4 Units<br>d. Voltage: 12 Vdc<br>e. Amp-Hour Rating: 40AH<br>f. Type: Rechargeable, Sealed Lead Acid (SLA) or Valve Regulated Lead Acid (VRLA)<br>g. Compatibility: Compatible to FDAS FACP |
|      |  | Fast Alarm Response of less than 3 seconds  |  |
|      |  | Can deliver up to eight audio messages (8 channels) simultaneously/ eight channels of multiplexed digital audio on a single pair of wires or fiber filament |  |
|      |  | Can Store up to 100 minutes pre-recorded audio messages capacity, can deliver both live and pre-recorded messages   |  |
|      |  | With embedded Graphic Command Interface Application and Operation   |  |
|      |  | With embedded communication bridge to Building Management System, compatible with Modbus, BACnet and Metasys protocols                                      |  |
|      | Atmospheric Lifetime   | ≤ 0.02 year   | ≤ 5 days   |

NPC-009.F17

Rev.No.1

Page 1 of 2

BIR Road cor. Quezon Avenue, Diliman  
Quezon City 1100, Philippines  
Tel. Nos. (632) 921-3541 to 80  
Fax No. (632) 921-2468  
Website: [www.napcor.gov.ph](http://www.napcor.gov.ph)



Management System  
ISO 9001:2015  
[www.tuv.com](http://www.tuv.com)  
ID: B103606260



|   | ITEM                       | DESCRIPTION           | FROM   |
|---|----------------------------|-----------------------|--------|
| 4 | LED Discharge Signage      | 1 pc                  | 2 pcs  |
|   | B. DETECTION COMPONENT     |                       |        |
|   | Network Communication Card | No quantity specified | 1 unit |
|   | Loop Controller Module     | No quantity specified | 1 unit |

**3. SECTION VIII- CHECKLIST OF TECHNICAL AND FINANCIAL DOCUMENTS AND BIDDING FORMS**  
 NPCSF-GOODS -02 List of all Ongoing Government & Private Contracts including contracts awarded but not yet started


- The listed attachments in the form are no longer needed to be submitted during bid opening, but are required during Post qualification:
  1. Notice of Award and/or Contract
  2. Notice to Proceed issued by the owner
  3. Certificate of Accomplishments signed by the owner or authorized
- Also, the following items which were erroneously numbered in the form should be corrected to wit:

| FROM                  | TO                    |
|-----------------------|-----------------------|
| Column 2              |                       |
| d. Owner's Name       | a. Owner's Name       |
| e. Address            | b. Address            |
| f. Telephone Nos.     | c. Telephone Nos.     |
| Column 6              |                       |
| d. Date Awarded       | a. Date Awarded       |
| e. Date Started       | b. Date Started       |
| f. Date of Completion | c. Date of Completion |

**Notes:**

1. All other terms published in the previous publication that are not amended by this publication shall remain the same.
2. For further clarification, you may contact us at (063)223-4604.

For the information and guidance of all concerned.

  
**REYNANTE T. CIRUELA**  
 Chairman, Bids and Awards Committee  
 Mindanao Generation

*Date of Publication: August 31, 2022*

