



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 1 to the Bid Documents for the:

SUPPLY AND DELIVERY OF ELECTRICAL SPARE PARTS FOR DISTRIBUTION LINE OF CLAVERIA DPP UNDER PR NO. S1-CLV25-001 / PB250122-CM00598 (EPA)

07 JANUARY 2025

All prospective bidders and authorized copy holders of the Bid Documents of the above-mentioned project are hereby advised of the changes and additional information in the Bid Documents, to wit:

A. SECTION VI PART I – TECHNICAL SPECIFICATIONS:

ITEM NO.	DESCRIPTION	QUANTITY	
		FROM	TO
3	FUSE LINK 1 AMP, UNIVERSAL, BOTTOM HEAD, TYPE K	15 PCS	<u>16 PCS</u>
4	FUSE LINK 2 AMP, UNIVERSAL, BOTTOM HEAD, TYPE K	16 PCS	<u>19 PCS</u>
5	FUSE LINK 3 AMP, UNIVERSAL, BOTTOM HEAD, TYPE K	20 PCS	<u>17 PCS</u>

B. DESCRIPTION OF ITEM NO. 6, INSULATOR POLE TOP PIN (POLYMER) 7 – 15 KV:

FROM	TO
Insulator Pole Top Pin (Polymer) 7 – 15kV	Insulator Pole Top Pin (Polymer) <u>(55-5)</u> 7 – 15kV

C. ADDITIONAL SPECIFICATIONS FOR ITEM NO. 12 (METER, kWhr):

<u>Meter, KWH, 1 Phase, Class 1, 240V, 10(60) A, 60Hz, 1600 imp/kWh, 0.2S, Bottom Connected, Electronic</u>

D. DESCRIPTION OF ITEM NO. 7 (INSULATOR SPOOL):

FROM	TO
Insulator Spool, 1-3/4, ansi class 53-4	Insulator Spool, 1-3/4, ansi class <u>53-2</u>

E. DESCRIPTION OF ITEM NO. 11 (PIN POLE TOP):

FROM	TO
Pin Pole Top, Spindle Pin Type (steel) (5/8 inch)	Pin Pole Top, Spindle Pin Type (steel) (5/8 inch) <u>(WITH THREAD)</u>

F. CLARIFICATIONS ON SECTION VI PART II – TECHNICAL DATA SHEETS:

QUERIES:	RESPONSE/CLARIFICATIONS:
1. What are the types of cores of Item Nos. 1 & 2 (Distribution Transformer 25KVA Pole Type & Distribution Transformer 50KVA Pole Type)?	THE TYPE OF CORE FOR ITEM NOS. 1 & 2 IS AMORPHOUS STEEL.



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
corner Quezon Avenue, Diliman, Quezon City 1100, Philippines
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468
Website: www.napocor.gov.ph




2. Is there a color requirement for Item No. 13 (Electric Meter Seal with Number Code)?	THERE IS NO COLOR REQUIREMENT, BUT IT IS MORE PREFERED FOR IT TO BE COLOR "BLUE".
3. Requesting for the length of the Cross Arm for Item No. 10 (Pin, Cross arm steel).	THE REQUIREMENT FOR THIS ITEM IS THE "PIN" FOR THE CROSSARM WHICH HAS A LENGTH OF 5/8 INCH, THUS THE CROSS ARM LENGTH IS IRRELEVANT.

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


LARRY I. SABELLINA
Vice President, Mindanao Generation Group,
and Chairman, Bids and Awards Committee