



NATIONAL POWER CORPORATION

SUPPLEMENTAL /BID BULLETIN NO. 2
to the Bid Documents for the:
SUPPLY AND DELIVERY OF CURRENT TRANSFORMERS AND POTENTIAL
TRANSFORMERS FOR MASBATE MINI-GRID PLANTS UNDER BOD
UNDER PR NO. S1-MMG25-003 / REF. NO. PB241203-NA00523

22 November 2024

All prospective bidders and authorized copy holders of the Bid Documents of the above-mentioned project are hereby advised of changes in the provisions in the bid documents, to wit:

A. DELIVERY PERIOD

FROM	TO
NINETY (90) CALENDAR DAYS	<u>ONE HUNDRED TWENTY (120) CALENDAR DAYS</u>

B. SECTION VI – TECHNICAL SPECIFICATIONS TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED a. To be submitted with the bid

Deletion of:
a.4 Approved Test Certificate from Energy Regulation Commission (ERC)

C. SECTION VI – TECHNICAL SPECIFICATIONS TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED b. To be submitted before/during delivery of spare parts

Inclusion of:
<u>b.4 Calibration Certificate traceable to National Standard</u>
<u>b.5 Approved Test Certificate from Energy Regulation Commission (ERC)</u>

D. SECTION VI – TECHNICAL SPECIFICATIONS PART I – TECHNICAL SPECIFICATIONS TS-2.0 SCOPE OF WORKS ITEM DESCRIPTION

ITEM	FROM	TO
1	CURRENT TRANSFORMER, Outdoor Type, Multi-ratio 20/15/10:5, Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: 0.3 Complaint to ANSI/IEEE C57.13/IEC/IEC 60044-1 Standard	CURRENT TRANSFORMER, Outdoor Type, Multi-ratio 20/15/10:5, Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: <u>0.2 or better for IEC Standard or 0.3 or better for ANSI Standard</u>
2	POTENTIAL TRANSFORMER, Outdoor Type, Ratio 8400V/120V (70:1), Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: 0.3 Complaint to ANSI/IEEE C57.13/IEC/IEC 60044-1 Standard	POTENTIAL TRANSFORMER, Outdoor Type, Ratio 8400V/120V (70:1), Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: <u>0.2 or better for IEC Standard or 0.3 or better for ANSI Standard</u>



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
corner Quezon Avenue, Diliman, Quezon City 1100, Philippines
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468
Website: www.napocor.gov.ph



E. SECTION VI – TECHNICAL SPECIFICATIONS PART II – TECHNICAL DATA SHEETS
ITEM 12 ACCURACY CLASS

ITEM	DESCRIPTION	NPC REQUIREMENTS	
		FROM	TO
1.0	CURRENT TRANSFORMER (CT)		
12	Accuracy Class	0.3	<u>0.2 or better for IEC Standard or 0.3 or better for ANSI Standard</u>
2.0	POTENTIAL TRANSFORMER (PT)		
12	Accuracy Class	0.3 WXY	<u>0.2 or better for IEC Standard or 0.3 or better for ANSI Standard</u>


F. ATTACHMENT 1 (BASIS OF ABC PER ITEM)

Refer to the attached “ATTACHMENT 1” for the basis of ABC per item. (1 page only)

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


ATTY. MELCHOR P. RIDULME
 Senior Vice President & COO and
 Chairman, Bids and Awards Committee

ATTACHMENT 1

PR NO. S1-MMG25-003

**SUPPLY AND DELIVERY OF CURRENT TRANSFORMERS AND POTENTIAL TRANSFORMERS FOR MASBATE
MINI-GRID PLANTS UNDER BOD**

ITEM	DESCRIPTION	PART NO.	QTY		UNIT PRICE	TOTAL PRICE
1	CURRENT TRANSFORMER, Outdoor Type, Multi-ratio 20/15/10:5, Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: 0.2 or better for IEC Standard or 0.3 or better for ANSI Standard		12	PC	₱ 97,350.00	1,168,200.00
2	POTENTIAL TRANSFORMER, Outdoor Type, Ratio 8400V/120V (70:1), Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: 0.2 or better for IEC Standard or 0.3 or better for ANSI Standard		12	PC	₱ 69,315.00	831,780.00
					TOTAL	1,999,980.00