

# NATIONAL POWER CORPORATION

# SUPPLEMENTAL /BID BULLETIN NO. 2

to the Bid Documents for the:

SUPPLY AND DELIVERY OF LINE HARDWARE FOR NORTHERN AND SOUTHERN PALAWAN SS AND 69KV TL UNDER PR Nos. S1-NPS23-002 & S1-SPS23-005/REF NO. PB230221-JD (PB2)

#### 26 JULY 2023

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the changes of the following:

## A. BID SUBMISSION/OPENING

# POSTPONED UNTIL FURTHER NOTICE

08 August 2023 9:30 A.M. Kañao Function Room

#### **B. DELIVERY PERIOD**

Ninety	(90)	Calendar	Dave
HILLOLY	(30)	Calellual	Days

One Hundred Twenty (120) Calendar Days

# C. ADDITIONAL INFORMATION FOR ITEM 1. Nos. 1, 8, 10, 11, 16 & 19

#### Item 1 (Steel Pole)

- See attached drawing (Annex A)

### Item 8 (Bolt lugs for grounding)

- 5/8" dia. X 1"

# Item 10 ( Cable, Grounding, Grounding Lead)

- Cable, Grounding, Grounding Lead wire, 10(3/8") Dia., Ordinary Grade Class "C"
- Quantity: 4 pcs

## Item 11 (Compression Clamp)

- Clamp for Grounding Rod
- Clamp, Compression Clamp, for 5/8" & 3/8 diameter for grounding.
- 5/8" & 3/8" diameter ground clamp

#### Item 16 (Clevis, Ball)

- Ball Clevis, Forged Steel, Galvanized, Clevis: 0.813" Opening, 0.625" Pin, UTS 30,000 lb; For use with class 52-3 & 52-5 insulators per ANSI Spec C-29.2-71
- Material: Body is Galv. Steel, Hardware is Galv. Steel & Cotter Pin is Stainless Steel

BIR Road cor. Quezon Avenue, Diliman Quezon City 1100, Philippines

Tel. Nos. (632) 921-3541 to80 • Fax No. (632) 921-2468

Website: www.napocor.gov.ph





SUPPLEMENTAL /BID BULLETIN NO. 2 SUPPLY AND DELIVERY OF LINE HARDWARE FOR NORTHERN AND SOUTHERN PALAWAN SS AND 69KV TL UNDER PR Nos. S1-NPS23-002 & S1-SPS23-005/REF NO. PB230221-JD (PB2)

**DATE: 26 JULY 2023** 

#### Item 19 (Porcelain type insulator)

-Type: Standard

-Applied standard: ANSI C29.2

-Class & Type: 52-3

-ANSI/NEMA: Ball & socket -Diameter of shell, mm: 254

-Unit spacing, mm: 146

-Total leakage distance, mm: 292

## D. ADDITIONAL INFORMATION FOR ITEM 2, No. 13

Item 13 (Clevis, Ball)

- Ball Clevis, Forged Steel, Galvanized, Clevis: 0.813" Opening, 0.625" Pin, UTS 30,000 lb; For use with class 52-3 & 52-5 insulators per ANSI Spec C-29.2-71
- Material: Body is Galv. Steel, Hardware is Galv. Steel & Cotter Pin is Stainless Steel

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

RENE B. BARRUELA

Vice President, Small Power Utilities Group and Chairman, Bids and Awards Committee

BIR Road cor. Quezon Avenue, Diliman Quezon City 1100, Philippines

Tel. Nos. (632) 921-3541 to80 • Fax No. (632) 921-2468

Website: www.napocor.gov.ph



