

### **National Power Corporation**

## SUPPLEMENTAL /BID BULLETIN NO. \_\_

to the Bid Documents for the:

SUPPLY AND DELIVERY OF 10KVA & 15KVA POWER TRANSFORMER FOR VARIOUS PLANTS UNDER EVOD UNDER PR NO. S2-EVO25-011/REF NO. PB241203-JD00513 (EPA)

#### **28 NOVEMBER 2024**

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the following changes:

#### A. ADDITIONAL INFORMATION FOR THE FOLLOWING SECTION:

- ATTACHMENT I
- SECTION VI PART I TECHNICAL SPECIFICATIONS CLAUSE TS-2.0 SCOPE OF WORKS
- SECTION VI PART II TECHNICAL DATA SHEETS CLAUSE 1.0 EQUIPMENT DATA
- SECTION VII SCHEDULE OF REQUIREMENTS

FROM	то
DISTRIBUTION TRANSFORMER 10 KVA Single Phase Type of Insulation Oil: Mineral Oil (PCB Free) Temperature Rise: 65°C Cooling: Oil Natural Air Natural Rated High Voltage: 13200GrdY/7620V Rated Low Voltage: 120/240V Rated Current: 1.31A to 41.7A Frequency: 60 Hz %Impedance (85°C) 2.0 ± 10% B.I.L High Voltage: 95kV Low Voltage: 30kV	DISTRIBUTION TRANSFORMER 10 KVA Single Phase Type of Insulation Oil: Mineral Oil (PCB Free) Temperature Rise: 65°C Cooling: Oil Natural Air Natural Rated High Voltage: 13200GrdY/7620V Rated Low Voltage: 120/240V Rated Current: 1.31A to 41.7A Frequency: 60 Hz %Impedance (85°C) 2.0 ± 10% B.I.L High Voltage: 95kV Low Voltage: 30kV  CORE MATERIAL: AMORPHOUS METAL TRANSFORMER  DESIGN TYPE: CONVENTIONAL





Gabriel Y. Itchon Building Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road) corner Quezon Avenue, Diliman, Quezon City 1100, Philippines Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468 Website: <a href="https://www.napocor.gov.ph">www.napocor.gov.ph</a>





## DISTRIBUTION TRANSFORMER 15 KVA

Single Phase

Type of Insulation Oil: Mineral Oil (PCB

Free)

Temperature Rise: 65°C

Cooling: Oil Natural Air Natural Rated High Voltage: 7620/13200Y Rated Low Voltage: 120/240 V Rated Current: 1.31A to 41.7A

Frequency: 60 Hz

%Impedance (85°C) 2.0 ± 10%

B.I.L High Voltage: 95kV Low Voltage: 30 kV

# DISTRIBUTION TRANSFORMER 15 KVA

Single Phase

Type of Insulation Oil: Mineral Oil (PCB

Free)

Temperature Rise: 65°C

Cooling: Oil Natural Air Natural Rated High Voltage: 7620/13200Y Rated Low Voltage: 120/240 V Rated Current: 1.31A to 41.7A

Frequency: 60 Hz

%Impedance (85°C) 2.0 ± 10%

B.I.L High Voltage: 95kV Low Voltage: 30 kV

CORE MATERIAL: AMORPHOUS METAL TRANSFORMER

**DESIGN TYPE: CONVENTIONAL** 

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

ATTY. MELCHOR P. RIDULME Senior Vice President & COO

and Chairman, Bids and Awards Committee