



NATIONAL POWER CORPORATION

SUPPLEMENTAL /BID BULLETIN NO. ___
to the Bid Documents for the:

**SUPPLY AND DELIVERY OF SF6 GAS CIRCUIT BREAKER FOR MASBATE
SUBSTATION AND 69KV TRANSMISSION LINES UNDER PR NO. S1-MS623-
002/REF NO. PB230215-JD**

06 FEBRUARY 2023

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the changes to wit:

**FULL SPECIFICATION FOR BREAKER, CIRCUIT, SF6 GAS FILLED, 72.5KV, 3P,
MOTOR-OPERATED SPRING, OUTDOOR LIVE TANK CIRCUIT BREAKER**

See attached "Annex A" – page 1

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


RENE B. BARRUELA

Vice President, Corporate Affairs Group and
Chairman, Bids and Awards Committee



0110

15252 K6-13Y1160025171



MADE IN INDIA

Circuit Breaker Type : EDF SK 1-1

Sr. No. 0077077MM007

Month & year of Mfg. JANUARY-1998

Voltage 72.5 kV Normal Current 1200 A

Lightning impulse withstand voltage 300 kV

Short circuit breaking current 12 kA

Short time withstand current & duration 19 kA 3 s

Operating sequence 0-0.3s-CO-3min-CO

First-pole-to-clear factor 1.5 Gas Pressure SF6/20°C(abs) 7.0 bar

Closing & Opening device supply voltage 125 Vdc

Motor supply voltage 240 VAC

Heater supply voltage 240 VAC

Mass (Approx) 1010 kg, Frequency 50 Hz

"Annex A"