



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 1  
to the Bid Documents for the:

UPGRADING OF VARIOUS TELEMETRY SYSTEMS OF FFWSO PROJECT UNDER PR  
NO. HO-FFW23-010 / PB231003-CM00289(PB3)

26 APRIL 2024

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the changes in the Bid Documents, to wit:

A. SECTION VI PART I – TECHNICAL SPECIFICATIONS (TS – 6.3.1.3 WATER LEVEL SENSOR, TECHNICAL REQUIREMENTS pages VI-TS-15 & VI-TS-16):

DESCRIPTION	FROM	TO
4. Accuracy	± 0.1%, full scale	± 0.1%, full scale, <b>or better</b>
5. Temperature Range	-25 deg C to +70 deg C	<b>0 deg C to +50 deg C</b>

B. SECTION VI PART II – TECHNICAL DATA SHEETS (ITEM 3.1.C – WATER LEVEL SENSOR page VI-TDS-8):

DESCRIPTION	FROM	TO
d. Accuracy	± 0.1%, full scale	± 0.1%, full scale, <b>or better</b>
e. Temperature Range	-25 deg C to +70 deg C	<b>0 deg C to +50 deg C</b>

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

**ATTY. MELCHOR P. RIDULME**  
Vice President, Office of the Legal Counsel and  
Chairman, Bids and Awards Committee



NATIONAL POWER CORPORATION  
Gabriel Y. Itchon Building  
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)  
corner Quezon Avenue, Diliman, Quezon City 1100, Philippines  
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468  
Website: [www.napocor.gov.ph](http://www.napocor.gov.ph)

