



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 1 to the Bid Documents for the:

SUPPLY, DELIVERY, INSTALLATION, TESTING, AND COMMISSIONING OF UNINTERRUPTIBLE POWER SUPPLY (UPS) UNDER PR NOS. HO-IST24-003 / REF. NO. PB240604-KB00266

27 MAY 2024

All prospective bidders and authorized copyholders of the Bid Documents of the project mentioned above are at this moment advised of the changes in the provisions of the Bid Documents, to wit:

Section VI: Technical Specifications PART I – TECHNICAL SPECIFICATIONS

FROM	TO
TS-3.0 DELIVERY PERIOD AND LOCATION The delivery period shall be Sixty (60) Calendar Days reckoned from the receipt of the Notice to Proceed.	The delivery period shall be One Hundred Twenty (120) Calendar Days reckoned from the receipt of the Notice to Proceed.
TS-5.0 GENERAL REQUIREMENTS Uninterruptible Power Supply (UPS) 5.4 Efficiency <ul style="list-style-type: none"> ▪ Normal operation $\leq 95\%$ ▪ Battery operation $\leq 95\%$ 	Uninterruptible Power Supply (UPS) 5.4 Efficiency <ul style="list-style-type: none"> ▪ Normal operation $\geq 95\%$ ▪ Battery operation $\geq 95\%$ Note: The revision shall also take effect on Item 6 Efficiency PART II – TECHNICAL DATA SHEETS
TS-5.0 GENERAL REQUIREMENTS Uninterruptible power Supply (UPS) 5.5 Power Supply Module <ul style="list-style-type: none"> ▪ Valve Regulated Lead-acid (VRLA) or better ▪ At least 3-1X16KVA power modules ▪ At least fifteen (15) minutes of backup time at $\geq 50\%$ connected load. 	Uninterruptible power Supply (UPS) 5.5 Power Supply Module <ul style="list-style-type: none"> ▪ Power module: At least 3-1X16KVA ▪ Battery module: Valve Regulated Lead-acid (VRLA) with fifteen (15) minutes runtime at $\geq 50\%$ connected load. ▪ Redundancy to the main module for high availability (HA). ▪ Static bypass switch to isolate the UPS, conduct troubleshooting and maintenance. Note: The revision shall also take effect on Item 7 Power Supply Module PART II – TECHNICAL DATA SHEETS



NATIONAL POWER CORPORATION
 Gabriel Y. Itchon Building
 Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
 corner Quezon Avenue, Diliman, Quezon City 1100, Philippines
 Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468
 Website: www.napocor.gov.ph




FROM	TO
<p>TS-5.0 GENERAL REQUIREMENTS</p> <p>Isolation Transformer</p> <p>5.9 Dry-type isolation transformer with metal-clad conduit and electrical protection.</p> <ul style="list-style-type: none"> ▪ Refer to Annex 1 (Drawing 001) 	<p>Isolation Transformer</p> <p>5.9 Dry-type isolation transformer with metal-clad conduit and electrical protection for 48KVA UPS capacity.</p> <ul style="list-style-type: none"> ▪ Refer to Annex 1 (Drawing 001) <p>Note: The revision shall also take effect on Item 16 PART II – TECHNICAL DATA SHEETS</p>
<p>TS-8.0 DOCUMENTS TO BE SUBMITTED</p> <p>To be submitted with the bid:</p> <p>8.5 The Supplier/Contractor must submit a certificate of Resellership from the Distributor of the offered brand, directly addressed to the BAC-NPC, indicating therein the PR/Preference number.</p> <p>Note: The Distributor's certificate of Resellership shall be current and valid on the bid opening date as advertised.</p>	<p>To be submitted with the bid:</p> <p>8.5 The Supplier/Contractor must provide a Manufacturer Certificate and Tier 1 Certificate authorizing them to sell and provide technical support, directly addressed to the BAC-NPC, indicating the PR/Preference number.</p> <p>Note: The certificate shall be current and valid on the bid opening date as advertised.</p>

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Terms of Reference (TOR) and prospective bidders.

For the Bids and Awards Committee:


ATTY. MELCHOR P. RIDULME
 Senior Vice-President & COO and
 Chairman, Bids and Awards Committee