



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 1

SUPPLY, ERECTION/INSTALLATION, TESTING AND COMMISSIONING OF 7.97/13.8kV DISTRIBUTION LINE (EXTENSION) AT SAN PASCUAL DPP – BRGY. CUEVA, SAN PASCUAL, MASBATE UNDER PR NO. HO-PIB24-003 / REF. NO. PB240116-AM00429

19 DECEMBER 2023

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the clarifications/changes, to wit:

SECTION III – BID DATA SHEET (ITB CLAUSE 20)

Clarifications: ITB Clause 20 – inserted with the following sentence:

- Documents to be submitted during Post-Qualification.

SECTION VI – TECHNICAL SPECIFICATIONS

B.7.5 – Household Wirings

4. Branch Circuit Conductor

Operating Temperature °C (NPC Requirements)

FROM	TO
90 °C	60 °C

SECTION VI – TECHNICAL SPECIFICATIONS

EW-2.9 FACTORY ASSEMBLY AND TESTS

EW-2.9.3 Field and Acceptance Test

Clarifications:

- All expenses incurred for the period of the Factory Acceptance Test shall be borne by the Contractor. Except in case NPC representative decides to witness the FAT physically, expenses shall be borne by NPC.

PROOF LOAD TO BE USED DURING THE FACTORY ACCEPTANCE TEST (FAT) OF THE SELECTED TYPE OF POLE.

Clarifications:

- QNC 45 – 570Kg proof load.
- RNC 45 – 890Kg proof load.

For the information and guidance of all concerned.

For the Bids and Awards Committee:

ATTY. MELCHOR P. RIDULME

Vice President, Office of the Legal Counsel
and Chairman, Bids and Awards Committee



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines
Tel. Nos. (632) 8921-3541 to80 • Fax No. (632) 8921-2468
Website: www.napocor.gov.ph

