



# NATIONAL POWER CORPORATION

## SUPPLEMENTAL / BID BULLETIN NO. 1

**SUPPLY, ERECTION/INSTALLATION, TESTING AND COMMISSIONING OF 7.97/13.8kV DISTRIBUTION LINE (EXTENSION) AT SAN PASCUAL DPP – BRGY. MABINI, SAN PASCUAL, MASBATE UNDER PR NO. HO-PIB24-004 / REF. NO. PB231228-AM00426**

**19 DECEMBER 2023**

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the clarifications/changes, to wit:

### **SECTION III – BID DATA SHEET (ITB CLAUSE 20)**

**Clarifications: ITB Clause 20 – inserted with the following sentence:**  
➤ Documents to be submitted during Post-Qualification.

### **SECTION VI – TECHNICAL SPECIFICATIONS**

**B.7.5 – Household Wirings  
4. Branch circuit conductor**

**Operating Temperature °C (NPC Requirements)**

<b>FROM</b>	<b>TO</b>
<b>90 °C</b>	<b>60 °C</b>

### **SECTION VI – TECHNICAL SPECIFICATIONS**

**EW-2.9 FACTORY ASSEMBLY AND TESTS**

**EW-2.9.3 Field and Acceptance Test**

**Clarifications:**

- All expenses incurred for the period of the Factory Acceptance Test shall be borne by the Contractor. Except in case NPC representative decides to witness the FAT physically, expenses shall be borne by NPC.



**NATIONAL POWER CORPORATION**  
Gabriel Y. Itchon Building  
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)  
Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines  
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468  
Website: [www.napocor.gov.ph](http://www.napocor.gov.ph)



**SECTION XI –ANNEXES (STAKING SHEETS)**

Clarification in the quantity of Primary Line Assemblies for Pole Nos. 38 and 60.


FROM	TO
11	1

**Additional Requirement:**

- **Certificate of Site Inspection to be submitted during Bid Opening.**

For the information and guidance of all concerned.

For the Bids and Awards Committee:



**ATTY. MELCHOR P. RIDULME**  
Vice President, Office of the Legal Counsel  
and Chairman, Bids and Awards Committee