



NATIONAL POWER CORPORATION

SUPPLEMENTAL /BID BULLETIN NO. 1
to the Bid Documents for the:

**SUPPLY, DELIVERY, AND TESTING OF AUTOMATIC CIRCUIT RECLOSER FOR
MROD POWER PLANTS UNDER PR NO. S1-MRO23-006/REF. NO. PB230227-JD**

16 FEBRUARY 2023

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the change to wit:

SECTION VI – PART II, TECHNICAL SPECIFICATIONS (E.1.0 AUTOMATIC CIRCUIT RECLOSER)

24. DC SUPPLY		24. DC SUPPLY	
e. Battery Operating Time after the Loss of the AC supply	At least 72 hours	e. Battery Operating Time after the Loss of the AC supply	At least 48 hours

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


RENE B. BARRUELA

Vice President, Corporate Affairs Group and
Chairman, Bids and Awards Committee

