



# NATIONAL POWER CORPORATION

## SUPPLEMENTAL / BID BULLETIN NO. 1 to the Bid Documents for the:

**SUPPLY AND DELIVERY OF SECURITY SPARE PARTS INTENDED FOR 200KW CUMMINS DIESEL ENGINE-MODEL NO. 6LTAA8.9-G2 AND SAONON STAMFORD MODEL NO. S275HCS OF POWER PLANTS UNDER MROD-SPUG UNDER PR NO. S1-MRO24-008 / PB240514-CM00219**

**26 APRIL 2024**

All prospective bidders and authorized copy holders of the Bid Documents of the above - mentioned project are hereby advised of the change in **SECTION VI PART I – TECHNICAL SPECIFICATIONS & PART II – TECHNICAL DATA SHEETS**, to wit:

ITEM	DESCRIPTION	QTY.	
		FROM	TO
3	AUTOMATIC VOLTAGE REGULATOR (AVR), MX321, (E000-23212), WITH ADJUSTMENT FOR OVER VOLTAGE, STABILITY, RAMP, DROOP, UNDER FREQUENCY ROLL OFF (UFRO), TRIM, DIP, OVER EXCITATION AND CURRENT LIMIT; SENSING INPUT VOLTAGE: 190-264VAC 3 PHASE; SENSING INPUT FREQUENCY: 50-60HZ NOMINAL; POWER INPUT (PMG) VOLTAGE: 170-220VAC 3 PHASE; POWER INPUT (PMG) CURRENT: 3A/PHASE; OUTPUT VOLTAGE: 120VDC MAXIMUM; OUTPUT CURRENT: CONTINUOUS 3.7A; RESISTANCE: 15 OHMS MINIMUM; DIMENSIONS: 2CM X 15CM X 20CM	1 UNIT	<u>2 UNITS</u>

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

**ATTY. MELCHOR P. RIDULME**  
Vice President, Office of the Legal Counsel and  
Chairman, Bids and Awards Committee



**NATIONAL POWER CORPORATION**  
Gabriel Y. Itchon Building  
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)  
corner Quezon Avenue, Diliman, Quezon City 1100, Philippines  
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468  
Website: [www.napocor.gov.ph](http://www.napocor.gov.ph)

