



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 2

SUPPLY, ERECTION/INSTALLATION, TESTING AND COMMISSIONING OF 7.97/13.8kV DISTRIBUTION LINE (EXTENSION) AT SAN PASCUAL DPP – BRGY. MABINI, SAN PASCUAL, MASBATE UNDER PR NO. HO-PIB24-004 / REF. NO. PB231228-AM00426 (PB2)

07 FEBRUARY 2024

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the clarifications/changes, to wit:

SECTION III – BID DATA SHEET (ITB CLAUSE 20)

Clarifications: ITB Clause 20 – inserted with the following sentence:

- Documents to be submitted during Post-Qualification.

SECTION VI – TECHNICAL SPECIFICATIONS

B.7.5 – Household Wirings

4. Branch circuit conductor

Operating Temperature °C (NPC Requirements)

FROM	TO
90 °C	60 °C

SECTION VI – TECHNICAL SPECIFICATIONS

EW-2.9 FACTORY ASSEMBLY AND TESTS

EW-2.9.3 Field and Acceptance Test

Clarifications:

- All expenses incurred for the period of the Factory Acceptance Test shall be borne by the Contractor. Except in case NPC representative decides to witness the FAT physically, expenses shall be borne by NPC.



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468
Website: www.napocor.gov.ph



SECTION XI –ANNEXES (STAKING SHEETS)

Clarification in the quantity of Primary Line Assemblies for Pole Nos. 38 and 60.

FROM	TO
11	1

ADDITIONAL REQUIREMENT:

Certificate of Site Inspection to be submitted during Bid Opening.

SECTION VI-TECHNICAL SPECIFICATIONS

B.7 Household Connection Materials

B.7.1 Service Drop Wire

b.7.2 Kilowatt-hour Demand Meter

Pls. refer/see attached revised Section VI-Technical Specifications
VI-EW-2-8

All other terms and conditions shall remain the same. Supplemental for clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:



ATTY. MELCHOR P. RIDULME

Vice President, Office of the Legal Counsel
and Chairman, Bids and Awards Committee

B.7 Household Connection Materials

	NPC Requirements	Contractor's Data
B.7.1. Service Drop Wire		
1. Manufacturer	By Contractor	
2. Place of Manufacture	By Contractor	
3. Type	#6 AWG Duplex	
4. Phase conductor		
a. Material	Aluminium	
b. Stranding no.	7 Al	
c. Insulation	Yes, black polyethylene (PE)	
5. Bare Neutral Messenger		
a. Material		
▪ Outer layers	Aluminium	
▪ Inner core	Steel	
b. Stranding no.	6-Al / 1-Stl	

B.7.2. Kilowatt-hour Demand Meter

	NPC Requirements	Contractor's Data
1. Manufacturer	By Contractor	
2. Place of Manufacture	By Contractor	
3. Accuracy Class	0.5 or better	
4. No. of Phase / Wire	1 / 2	
5. Voltage, V	230	
6. Current Range	10 (30)	

Name of Firm

Name & Signature of Representative

Designation

