

NATIONAL POWER CORPORATION

SUPPLEMENTAL /BID BULLETIN NO. 2
to the Bid Documents for the:

SUPPLY, DELIVERY, INSTALLATION, TEST AND COMMISSIONING OF 40 MVA, 69 KV/13,8 KV, 3-PHASE, 60 HZ POWER TRANSFORMER FOR AGUS 6 UNIT 1 & 2 UNDER P.R. NO. MG-A7C23-014/REF.NO. PB230912-JD00257

07 SEPTEMBER 2023

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the following changes:

A. SECTION III – BID DATA SHEET (SINGLE LARGEST COMPLETED CONTRACT), ITB CLAUSE 5.3

FROM	TO
For this purpose, similar contracts shall refer to Supply, Delivery, Installation, Test and Commissioning of High Voltage Electrical Equipment such as Power Transformers with at least same voltage level and a rating of at least 40MVA .	For this purpose, similar contracts shall refer to Supply, Delivery, Installation, Test and Commissioning of High Voltage Electrical Equipment such as Power Transformers with at least same voltage level and a rating of at least 30MVA .

B. SECTION VI – TECHNICAL SPECIFICATIONS (TECHNICAL DATA SHEETS - POWER TRANSFORMER)

FROM	TO
Item 6. a Primary, kV: 75	Item 6.a Primary, kV: 72.5
Item 9 – Type of Cooling: ONAN/ONAF	Item 9 – Type of Cooling: ONAN/ONAF Capacity for ONAF is 70% of 40 MVA
Item 23 – Power Frequency Withstand Voltage (kV)	Item 23 – Power Frequency Withstand Voltage (kV) c. Neutral Winding = 95
Item 24 – Lightning Impulse Withstand Voltage (kV)	Item 24 – Lightning Impulse Withstand Voltage (kV) c. Neutral Winding = 250
Item 30 – Bushings c. Power Frequency Voltage, kV Neutral = 105	Item 30 – Bushings c. Power Frequency Voltage, kV Neutral = 95
No Site Inspection will be required.	Site Inspection will be required during the post-qualification. Hence, prospective bidders shall visit and inspect the site and secure a certificate from Agus 6 HEP.




Item 33 Surge Arrester mounted on Transformer and Item 37 - Annunciator	No recommended brands and quantity for Item 37 must be complete with all the required signals and alarms per Manufacturer design.
Item 50 (b) Set of Special Tools	As per Manufacturer recommendations

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:



ATTY. MELCHOR P. RIDULME
Vice President, Office of the Legal Counsel
and Chairman, Bids and Awards Committee