



National Power Corporation

MINUTES OF PRE-BID CONFERENCE

CIRCUIT BREAKER AG5 CIRCUIT BREAKER, GENERATOR, 13.8 KV (PR No. MG-A5C21-001/PD. Ref. PB21-1021-MGEC-006)

DATE : December 9, 2020
 TIME : 9:00 AM
 VENUE : BAC Bidding Room, MinGen Headquarters
 BID OPENING : December 22, 2020

Attendees:

BIDS AND AWARDS COMMITTEE (BAC)

Chairman:

H.L. MACADATAR - Dept. Manager, CMTSD

Vice-Chairman:

ATTY. A. R. MAMAILAO - Corp. Atty. B, LSD-OVP

Members:

J.P. MAGHINAY - Sr. Accountant, AFD, Financial
R.T. CIRUELA - Div. Manager, TSD-CMTSD, Technical
E.H. C.MADRIO - O/M Manager, Agus 5 HEP, End-user

TECHNICAL WORKING GROUP (TWG)

Chairman:

R. F. CASTILLANO - Prin. Engr. A., TSD-CMTSD

Vice-Chairman:

ATTY. A. E. MACABANGKIT - Corp. Atty. A, LSD-OVP

Members:

I. O. PALERMO - OIC-Corporate Staff Officer - OVP, Technical
M.V. POTTER - Sr. Financial Spelst B, AFD, Financial
V. R.DELA ROSA, JR. - Acting Plant Supt., Agus 5 HEP, End-user

BAC SECRETARIAT

GOODS

Head:

E.C.PADAYHAG - Acting Mat'ls. Management Officer, PSS, Logistics

Members:

E. B. JARALES - Mat'ls. Management Specialist C, PSS, Logistics
L.A. MONTEFALCON - Corp. Staff Specialist B, B&S-OVP
R.O. SALOMON - IS/IT Specialist, OM-AFD

PROSPECTIVE BIDDERS

COMPANY NAME

NAME OF REPRESENTATIVE

- No interested bidder has purchase the Philippine Bidding Documents (PBD) yet as to the time when this Pre-bid conference was conducted.

Name of Bidder/s	Bidder's Concerns/Queries	Remarks / Agreement
IPower	Site Inspection: Our technician had previously visited the site, do we need to visit again?	Previous visit will already suffice considering that there is still a travel restriction being imposed due to the Covid19 Pandemic.
NEMA	Can we offer a different brand but compatible with the existing brand?	We will accept any refutable brand as long as there would be no retrofitting to be made during installation, meaning, the offered unit is exactly the same in auxiliary/terminal connections and mounting of the existing unit of the plant. Provided also that participating bidder will provide a Manufacturer's Technical Drawing (Electrical & Physical Dimension) to ensure that the offered product will fit with the existing mounting of the plant.

I. AGREEMENTS


1. FOR SUPPLEMENTAL BID BULLETIN:


- a If participating bidder's offered product's brand is not the same with the existing Circuit Breaker of the Plant, said bidder must provide Manufacturer's Technical Drawing (Electrical & Physical Dimension) to ensure that the offered product will exactly fit with the existing mounting of the plant.
- b Delivery Period:
From : 120 Calendar Days
To : 240 Calendar Days
- c Track Record
From : Supply and delivery of Medium.High Voltage Equipment for the last Five (5) years
To : Supply and delivery of Medium.High Voltage Equipment for the last Ten (10) years
- d DELETE a portion of Item 2a of Section VII. Technical Specifications of the PBD to exclude Diagnostic Software requirement.

2. All other technical and administrative requirements of the Pre-Procurement Conference, TOR and the Checklist of Documents not specifically modified/amended during the Pre-bid conference shall remain effective and must be strictly complied/submitted. Failure to comply with any of the foregoing requirements/agreements and those required by the PR and checklist will result to disqualification.

Prepared by:

L.A. MONTEFALCON
Member, Secretariat (Goods)

Reviewed By:

R. F. CASTILLANO
Chairman, TWG, Goods

Approved By:

H. L. MACADATAR
Chairman
Bids and Awards Committee